



Government of Karnataka



**Office of the District Fire Officer, Karnataka State Fire and Emergency Services,
Mysuru District, Saraswathipuram, Mysuru-09.**

Tel : 0821-2493101

Email : dfomyuru.ksfes[at]ka.gov.in

Mob : 9480823660

No: 06/FSR/DFO/MY/2026-27

Date:-17-04-2026.

To,

The Principal.

Eklavya Model Residential School (ST)

Sollepura Village, H.D.Kote Taluk,

Mysuru District-571114.

U Disc Code:-29260312906.

**Sub : Issued the 'Fire safety recommendation' to existing educational building
of "Eklavya Model Residential School (ST)" building at Sollepura Village,
H.D.Kote Taluk, Mysuru district-571114.**

Ref : Your request letter, dated:-07-04-2026.

><><>*@*<><><

With reference to the subject above cited the premises of existing educational building of "Eklavya Model Residential School (ST)" building at Sollepura Village, H.D.Kote Taluk, Mysuru district-571114, was inspected by me on 07-04-2026 with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises and has submitted the details as under.

ANNEXURE-B

"Group B Educational Buildings"

***NBC-2016, Part-4, Table 7(11)3.1.3 Group B Educational Buildings
sub division B1 & B2.***

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 & As per Government Order HD 210 SFB 2025, Bangalore, date:-12-01-2026.)

Part-A. Details of the building / premises :-

Sl. No.	Details	:	Observation
01.	Name and Address of the Applicant.	:	The Principal. Eklavya Model Residential School (ST) Sollepura Village, H.D.Kote Taluk, Mysuru District-571114.
02.	Name and Address of the premises.	:	Eklavya Model Residential School (ST) Sollepura Village, H.D.Kote Taluk, Mysuru District-571114.
03.	Name and address of the Building owner	:	The Principal. Eklavya Model Residential School (ST) Sollepura Village, H.D.Kote Taluk, Mysuru District-571114.



04.	Number of buildings	:	One School building.
05.	Number of floors	:	Ground + First floor
06.	Floor wise details of Occupancy.	:	Ground floor:- Portico, Physics lab, Biology lab, Entrance, Principal office, Computer lab, Electronics lab, Botany lab, Office, 05 Store, Chemistry lab, Sports room, 02 Staff toilets & 02 Boys toilets. First floor:- 10 Class rooms. Staff room, Records room, 04 Store, 02 Staff toilets & 02 Boys toilets.
07.	Height of the building	:	08.30 Mtrs.
08.	Site area	:	20 Acre
09.	Built-up area of each floor	:	Ground floor:- 1050.00 Sq. mtrs First floor:- 1050.00 Sq. mtrs
10.	Total built-up area	:	2100.00 Sq.mtrs.
11.	<u>Surrounding properties:-</u>		
	South (front)	:	09.00 mtrs wide road.
	North (rear)	:	Open Ground
	East (side)	:	Remaining Property
	West (side)	:	Boys Hostel
12.	<u>Open space all around the building :-</u>		
	South (front)	:	Nil
	North (rear)	:	03.80 Mtrs.
	East (side)	:	03.80 Mtrs.
	West (side)	:	Nil
Allowed setback (open space) should be maintained free from further obstruction / construction.			

Part-B. On inspection of this Educational premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view:-

Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)
01.	Accessibility to the premises	This premise is abutting 09.00 mtrs. width main road on southern side. This road is hardened to carry the weight of 45,000 kgs.	Complied.
	No. of entrances	01 entrance cum exit , Width of 03.50 mtrs.	Complied.



03.	No. of staircases available	Nos. of staircases	01 no.	Complied.
		Width of staircases	01.90 mtrs	
		Width of treads	30 cms	
		Height of risers	15 cms	
		Nos. of riser per flight	07 nos.	
		Height of handrails	00.90 mtrs.	
		Head room clearance	02.50 mtrs.	
04.	Portable Fire Extinguisher	Not provided.		1. One ABC type fire extinguisher of 6 kgs capacity for every 100 m² radius. 2. One CO2 type fire extinguisher, of 4.5 kgs capacity shall be provided near electrical panel board.
05.	Escape routes	Not marked.		Directions in which the student's should have to move in the event of any emergency have to be indicated in the corridor/passage as a guide during evacuation. These marking should be in luminous paint.
06.	Fire order (Fire Safety plans)	Not displayed.		A notice board indicating the action to be taken by the employees in case of any emergency should be displayed along with the telephone number of H.D.Kote Fire Station 08228-296101 & 101 and the telephone number of nearest ambulance service



			& Police station.
07.	No Smoking board.	Not displayed.	As per Sec-4 of COPTA a board with words NO SMOKING AREA shall be written in English & Kannada both languages shall be prominently displayed at inside the entry / exit of the each floor.
08.	Fire Siren	Not installed.	A Fire Siren shall be installed in the Premises to inform the student's in case of a fire emergency and evacuate the area.
09.	Nominate one Fire Nodal Officer	Not imparted.	A Fire nodal officer shall be nominated either from teaching or non teaching staff.
10.	Training in Fire fighting	Not imparted.	At-least 40% of Teaching and non teaching staff should be got trained in fire fighting at Regional Training Centre, Hebbal Fire Station Premises, Mysuru.

Fire precautionary measures.

- Explosive and flammable material should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.
 - Accumulation of combustible waste in and around the premises should be avoided.
 - The exit ways shall be always kept clear without any obstruction.
 - Liquefied petroleum gas should not be stored in the building except in the Kitchen (Provided for Mid-Day Meal Preparation)
 - The doors shall not be kept locked / latched during working hours and shall be free from obstruction.
 - During the class hours the class room doors shall not be locked from inside to outside.
- As per Hon'ble supreme court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordinate with fire service department.




Under the above circumstance the Karnataka Fire & Emergency Service Department is issuing 'Fire Safety Recommendation' to "Eklavya Model Residential School (ST)" building at Sollepura Village, H.D.Kote Taluk, Mysuru district-571114, subject to condition and compliance of the above recommendations in within 3 months and compliance to the undersigned.

"This Fire Safety Recommendation is valid for only one year from the date of issue".

♣ All requirements recommended above are as per National Building code-2016 Part-4 Clause 3.1.3 of Fire and Life safety will have to be complied with mandatorily.

Yours faithfully,


District Fire Officer
Karnataka State Fire and
Emergency Services
Mysuru District, Mysuru

Copy to with respects:

Submitted to the Director General of Police
and Director General,
Karnataka State Fire and Emergency Services,
Bengaluru-42.